

Sr. GM (NWO-CFA),  
BSNL Corporate Office,  
Bharat Sanchar Bhawan,  
H.C.M Lane, Janpath, New Delhi-1  
Tel No 23714455, Fax No 23354549  
Email:nwocfa@bsnl.co.in



भारत संचार निगम लिमिटेड  
(भारत सरकार का उपक्रम)  
BHARAT SANCHAR NIGAM LIMITED  
(A Govt. of India Enterprise)

No.: 7-1/2015/PHT/NWO-CFA/Fire

Dated: 08-10-2015

To,  
All Chief General Manager,  
Telecom Circle/Telecom Districts/Mtce. Region,  
BSNL

**Sub.:- Regarding safety from Fire incidents**

Recently a fire incident had occurred in MDF room at Anakapally MBM C-DOT Telephone Exchange, Vishakhapatnam in A.P. Telecom circle. Investigation committee has suggested the following measures are to be taken to avoid such fire incident in future.

1. It is advised to relocate the U/G cable away from the Electrical transformer pole and immediate provisioning of earth to all pillars.
2. It is advised for earthing of U/G cable at equal interval to maintain a minimum length of parallelism thereby reducing the induction voltage.

Apart from above, all existing guidelines & other instructions issued by this office time to time including engineering instructions on prevention of fire in telecommunication buildings & fire fighting should also be strictly followed.

*Mukesh Meena*  
8/10/15  
(Mukesh Meena)  
DGM (NWO-I CFA)

Copy to: CGM, Inspection Circle for information please.